

EC3-122403DSL - 12KW 240/415V







TERMINAL POST DETAIL **ELEMENT WIRE SCREW WASHER** $M5 \times 30$ **CERAMIC** PAN HEAD SCREW-**WASHER** NUT **WASHER WIRE WASHER** NUT **EYELET** SHAKEPROOF WASHER **NUT EYELET** METRIC TOLERANCES UNLESS SPECIFIED Drawn TITLE AIRTEC AIR HEATER EC3-122403DSL S.T.

12KW 240/415V 3 PHASE STAR UNIT - 14.4 Ohms PER ELEMENT / ZONE 20 SWG SPIRAL ON A Ø4mm MANDREL APPROX. 21" WIND - 52" STRETCH - LEAVE 12" STRAIGHT ON ENDS FIT GLASS FIBRE LEADS 16" LONG - 6 x 20 AMP FIT ALL LEADS WITH YELLOW INSULATED EYELETS MARK LEADS WITH SHRINK TUBE AS DRAWING - DO NOT SHRINK ON - FASTEN WITH CABLE TIE FEED STRAIGHT LEGS THROUGH HOLES IN FORMERS

AND WRAP AROUND TERMINAL SCREWS. MARK SIDES OF TOP CERAMIC WITH:

HEA1017 12KW 240/415V EC3-122403DSL Job no. Customers order no.

ELEMENT WIRING LAYOUT

REV	REVISION	DATE
1	WIRE CHANGE FROM	
	19SWG ON Ø4.5 TO 20SWG	
	ON Ø4	

AIR HEATER 12KW 240/415V - FOR USE IN CONTINUOUS AIR **FLOW**

2 PLACES OF DECIMALS ± 0.05 1 PLACE OF DECIMALS $\pm \ 0.10$ ± 0.25 300 & OVER ± 0.50 THREADS TO BE BS 3643 (MEDIUM FIT)

Checked Date 18/10/2017 DRAWING No. EC3-122403DSL